



# 中国国家强制性产品认证证书



证书编号：2020322303000665

认证委托人名称：美卡诺元器件（上海）有限公司  
 认证委托人地址：上海市嘉定区南翔镇嘉前路 1001 号  
 生产者名称：美卡诺元器件（上海）有限公司  
 生产者地址：上海市嘉定区南翔镇嘉前路 1001 号  
 生产企业名称：美卡诺元器件（上海）有限公司  
 生产企业地址：上海市嘉定区南翔镇嘉前路 1001 号

产品名称：防爆接线箱  
 系列、规格、型号：05 系列，06 系列，35 系列，15 系列，16 系列，36 系列  
 标准：GB 3836.1-2010、GB 3836.3-2010、GB 3836.4-2010、  
 GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020 年 8 月 19 日                      有效期至：2025 年 8 月 18 日

首次发证日期：2020 年 8 月 19 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批 准：



## 上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322303000665**

**APPLICANT:** Mecano Components (Shanghai) Co., Ltd  
**ADDRESS:** Jiaqian Road Nanxiang Hi-tech Park No.1001, Shanghai, P.R.China  
**MANUFACTURER:** Mecano Components (Shanghai) Co., Ltd  
**ADDRESS:** Jiaqian Road Nanxiang Hi-tech Park No.1001, Shanghai, P.R.China  
**FACTORY:** Mecano Components (Shanghai) Co., Ltd  
**ADDRESS:** Jiaqian Road Nanxiang Hi-tech Park No.1001, Shanghai, P.R.China

**PRODUCTNAME:** Junction box  
**SERIES,SPECIFICATION,MODEL:** 05 series, 06 series, 35 series, 15 series, 16 series, 36 series  
**STANDARDS:** GB 3836.1-2010、GB 3836.3-2010、GB 3836.4-2010、  
 GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**August 19, 2020

**Valid until:** August 18, 2025

**Date of original certification:**August 19, 2020

**The validity of this certificate is subject to positive result of the regularfollow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Xu JianPing



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0000396



# 中国国家强制性产品认证证书



证书编号: 2020322303000665

## 附件

产品名称: 防爆接线箱

型号规格: 05. **a b c**, 15. **a b c**, 其中  
**a** 可选代码为: 06, 08, 10, 12, 14, 16, 18, 23, 31, 60  
**b** 可选代码为: 06, 08, 10, 12, 13, 14, 15, 16, 18, 20, 22, 25, 26, 28, 33, 36, 40, 56, 60  
**c** 可选代码为: 03, 05, 06, 06C, 08, 08C, 09, 10, 11, 14, 18, 20, 23  
 06. **a b c**, 16. **a b c**, 其中  
**a** 可选代码为: 08, 12, 16, 20, 25, 30, 36, 40, 41, 88  
**b** 可选代码为: 01, 02, 03, 08, 11, 12, 16, 19, 20, 22, 23, 26, 30, 36, 40, 56, 60  
**c** 可选代码为: 00, 06, 08, 09, 12, 16, 20  
 35. **a b c**, 36. **a b c**, 其中  
**a** 可选代码为: 00, 06, 10, 15, 20, 30, 38, 40, 50, 60, 99  
**b** 可选代码为: 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 15, 20, 22, 30, 32, 33, 38, 40, 44, 53, 63, 64, 99  
**c** 可选代码为: 00, 06, 08, 09, 12, 15, 16, 21, 99

防爆标志: Ex e IIC T4~T6 Gb, Ex tD A21 IP66 T80°C/T95°C/T130°C, Ex ia IIC T4~T6 Ga, Ex ib IIC T4~T6 Gb

电气参数: 最高额定电压 1100V, 最高额定电流350A。

批准:



## 上海仪器仪表自控系统检验测试所有限公司