

# CERTIFICATE

## (1) EU-Type Examination

- (2) **Equipment or protective systems intended for use in potentially explosive atmospheres - Directive 2014/34/EU**

(3) EU-Type Examination Certificate Number: **DEKRA 18ATEX0120 X** Issue Number: **0**

(4) Product: **Power distribution, switchgear and control box Series GUB**

(5) Manufacturer: **Rose Systemtechnik GmbH**

(6) Address: **Erbeweg 13-15, 32457 Porta Westfalica, Germany**

(7) This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., Notified Body number 0344 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential test report number NL/DEK/ExTR19.0094/00.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0 : 2018**

**EN 60079-1 : 2014**

**EN 60079-31 : 2014**

except in respect of those requirements listed at item 18 of the Schedule.

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

(11) This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

(12) The marking of the product shall include the following:



**II 2 G Ex db ... IIB or IIC T4, T5 or T6 Gb**  
**II 2 D Ex tb ... T85 °C, T100 °C or T135 °C Db**

Date of certification: 14 November 2019

DEKRA Certification B.V.

R. Schuller  
Certification Manager

Page 1/3



® Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 18ATEX0120 X**

Issue No. **0**

(15) **Description**

Power distribution, switchgear and control assembly Series GUB, made of aluminium, stainless steel or cast iron with a threaded cover, with or without display window, are intended to be used in potentially explosive atmospheres. Inside and in the walls or cover of the enclosure electrical apparatus such as terminals, switching-, control-, regulating-, measuring- and indicating devices can be mounted.

The GUB series consist of 12 types:

- GUB 01 ... GUB 06: enclosures in 6 different sizes, without display window;
- GUB 01W ... GUB 06W: enclosures in 6 different sizes, with display window.

**Marking**

Where applicable, the equipment marking is completed by the types / levels of protection "I", "[I]" and/or "m".

The equipment is marked with Group IIB if at least 20% of each internal cross-sectional area remains free; it may be marked with Group IIC if at least 40% of each internal cross-sectional area remains free.

**Ambient temperature range**

Maximum ambient temperature range (for details see table below):

- GUB 01 ... GUB 06: -20 °C to +110 °C
- GUB 01W ... GUB 06W: -20 °C to +75 °C

**Degree of ingress protection**

Degree of protection IP66 according to EN 60529 and EN 60079-0.

**Electrical ratings**

The electrical ratings are dependent on the built-in components and equipment, but do not exceed 1,1 kV ac/dc nominal, 415 A and 240 mm<sup>2</sup>. Actual ratings are stated on the nameplate.

**Options**

The threaded flamepaths may be provided with a max. 0,008 mm thick electro-plating.

The enclosures may be supplied in natural finish, electro-plated, powder coated or liquid painted. The painting thickness does not exceed 0,18 mm.



(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 18ATEX0120 X**

Issue No. **0**

**Thermal data**

The relation between GUB type, temperature class, maximum surface temperature, maximum ambient temperature and maximum allowed power dissipation is given in the table below.

Temperature class	T6			T5					T4				
Max. surface temperature*	T85 °C			T100 °C					T135 °C				
Maximum ambient temperature (°C)	40	50	60	40	50	55	60	75	40	50	60	90	110
GUB Type:	Maximum allowed power dissipation (W):												
01	82	-	38	-	-	82	-	38	-	-	-	82	38
01W	-	-	-	-	-	-	-	-	-	-	-	-	-
02	86	-	45	-	-	86	-	45	-	-	-	86	45
02W	-	-	-	-	-	-	-	-	-	-	-	-	-
03	114	-	64	-	-	114	-	64	-	-	-	114	64
03W	-	-	-	-	-	-	-	-	-	-	-	-	-
04	170	120	70	230	180	170	126	70	410	376	316	170	70
04W	-	-	-	-	-	-	-	-	-	-	-	-	-
05	218	168	91	291	226	218	159	91	491	451	400	218	91
05W	-	-	-	-	-	-	-	-	-	-	-	-	-
06	250	182	150	405	282	250	215	150	723	609	472	250	150
06W	-	-	-	-	-	-	-	-	-	-	-	-	-

\* : values have been determined without a dust layer  
 - = ...W types are not suitable for T4 / T135 °C

**Installation instructions**

The instructions provided with the product shall be followed in detail to assure safe operation.

(16) **Report Number**

No. NL/DEK/ExTR19.0094/00

(17) **Specific conditions of use**

1. For enclosures provided with a powder coating, liquid painting or provided with a non-metallic nameplate and/or tagplate and intended for use in Group III applications, the user shall minimize the risk from electrostatic discharge by suitable selection and installation.
2. The threaded flame path of the cover is more than required by EN 60079-1. Contact the manufacturer for information on the dimensions of the flameproof joints.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at item (9).

(19) **Test documentation**

As listed in Report No. NL/DEK/ExTR19.0094/00

(20) **Certificate history**

Issue 0 - 222966700 initial certificate