



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx PTB 07.0060

Issue No: 4

Certificate history:

Status: **Current**

Issue No. 4 (2018-03-23)

Issue No. 3 (2012-02-29)

Date of Issue: **2018-03-23**

Page 1 of 4

Issue No. 2 (2010-12-17)

Issue No. 1 (2010-08-04)

Issue No. 0 (2007-11-05)

Applicant: **ROSE Systemtechnik GmbH**
Erbeweg 13 - 15
32457 Porta Westfalica
Germany

Equipment: **Connection and Junction Box and Control Box Type 35. XX XX XX and 36. XX XX XX.**

Optional accessory:

Type of Protection: **Different**

Marking:

Ex db eb ia [ia] mb IIC T4, T5, T6 Gb
Ex tb IIIC T 85 °C, T 100 °C, T135 °C Db

Approved for issue on behalf of the IECEx
Certification Body:

Dr.-Ing. Detlev Markus

Position:

Head of Section "Explosion Protection in Energy Technology"

Signature:
(for printed version)

D. Markus

Date:

10.03.18

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

Physikalisch-Technische Bundesanstalt (PTB)
Bundesallee 100
38116 Braunschweig
Germany





IECEX Certificate of Conformity

Certificate No: IECEx PTB 07.0060 Issue No: 4
Date of Issue: 2018-03-23 Page 2 of 4
Manufacturer: ROSE Systemtechnik GmbH
Erbeweg 13 - 15
32457 Porta Westfalica
Germany

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2017 Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirements
IEC 60079-1 : 2014-06 Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-18 : 2014 Edition:4.0	Explosive atmospheres - Part 18: Equipment protection by encapsulation "m"
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
IEC 60079-7 : 2015 Edition:5.0	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[DE/PTB/ExTR07.0060/04](#)

Quality Assessment Report:

[DE/EPS/QAR17.0003/03](#)



IECEX Certificate of Conformity

Certificate No: IECEx PTB 07.0060

Issue No: 4

Date of Issue: 2018-03-23

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Description of equipment

The Connection and Junction Box and Control Box type 35. XX XX XX und 36. XX XX XX consists of enclosures out of sheet steel or stainless steel in the type of protection Increased Safety "e" and Protection by enclosure "tb", which are provided for stationary assembly. They are equipped with terminals for circuits in the type of protection Increased Safety "e" or Intrinsic Safety "ia" or combinations of both. The components for intrinsically safe circuits are marked, e.g. in light blue. Connection is by means of Ex-type cable entries. The empty enclosures as well as all mounted and attached components have been tested and certified under a separate examination certificate.

Technical data, Nomenclature, Notes for manufacturing and operation and Assembly tables see Annex.

SPECIFIC CONDITIONS OF USE: NO



IECEX Certificate of Conformity

Certificate No: IECEx PTB 07.0060

Issue No: 4

Date of Issue: 2018-03-23

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Update of the state of standards IEC 60079-0:2018 (Ed. 7), IEC 60079-7:2015 (Ed. 5),

IEC 60079-11:2011(Ed.6); IEC 60079-18:2015 (Ed.2); IEC 60079-31:2013 (Ed. 2)

Annex:

[Annex_Manufacturing_Locations_070060X-04.pdf](#)

[COCA_070060-04.pdf](#)



Applicant: ROSE Systemtechnik GmbH
Erbeweg 13-15
32457 Porta Westfalica
Germany

Electrical Apparatus: Power distribution, switch and control gear assembly type
05.XX XX XX and 15.XX XX XX


List of Manufacturing Locations:

1. Rose Systemtechnik GmbH
Erbeweg 13-15
32457 Porta Westfalica
Germany
2. Phoenix Mecano (India) Private Limited
Plant - I & II, Pirangut Industrial Area, Post Ghotawade, Plot 288/389
Village Bhare, Taluka Mulshi, Dist Pune – 412 115
India
3. Phoenix Mecano (India) Private Limited
Plant - III, GatNo 408, 410 & 412
Village Urse, Taluka Maval, Talegaon Urse Road, Dist Pune - 410 506
India
4. Phoenix Mecano S.E. Asia Pte. Ltd.
35 Ubi Ave 3#04-01, Colorscan Building
Singapore 408863
Singapore
5. Phoenix Mecano Kecskemet KFT
Istvan kiraly krt. 24
6000 Kesckemet
Hungary
6. Phoenix Mecano Inc.
7330 Executive Way
MD 21704 Frederick
United States
7. PM Komponenten N. V.
Karrewegstraat 124
9800 Deinze
Belgium



-
8. PM Komponenten B. V.
Havenstraat 100
7005 AG Doetinchem
Netherlands

 9. Mecano Components Co. Ltd/012
No. 1001, Jiaqian Road, Nanxiang, Jiading District
Shanghai P.R.C. 201802
China



Applicant: ROSE Systemtechnik GmbH
Erbeweg 13-15
32457 Porta Westfalica
Germany

Electrical Apparatus: Connection and Junction Box and Control Box
Type 35.XX XX XX and 36.XX XX XX

Description

The Connection and Junction Box and Control Box type 35. XX XX XX and 36. XX XX XX consists of enclosures out of sheet steel or stainless steel in the type of protection Increased Safety "e" and Protection by enclosure "tb", which are provided for stationary assembly. They are equipped with terminals for circuits in the type of protection Increased Safety "e" or Intrinsic Safety "ia" or combinations of both. The components for intrinsically safe circuits are marked, e.g. in light blue. Connection is by means of Ex-type cable entries. The empty enclosures as well as all mounted and attached components have been tested and certified under a separate examination certificate.

Technical Data

Ambient temperature:

- 55 °C to +90 °C: with gasket out of silicon
- 40 °C to +90 °C: with gasket out of HF
- 40 °C to +90 °C with PU-foam
- 20 °C to +85 °C with gasket out of CR
- 50 °C to +85 °C with window out of PC
- 20 °C to +85 °C with window out of glass


Degree of protection: IP66

Rated voltage: Up to 1500 V
Rated current: Max. 500 A
Conductor size: Max. 300 mm²
Protective cross section: Max. 150 mm²

Nomenclature

XX.	**	**	**
1	2	3	4

- 1: Type, material Polyester
- 2: Length
- 3: Width
- 4: Depth




Attachment to Certificate
IECEx PTB 07.0060 Issue 4



Enclosure standard and max. Power Dissipation of **Ex Stainless Steel Enclosure**:

Type reference: Empty enclosure
34.XX XX XX Ex Stainless Steel Standard
Increased Safety
35.XX XX XX Ex Stainless Steel Standard
Intrinsic Safety / mixed assembled
36.XX XX XX Ex Stainless Steel Standard

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.10 10 06	100	100	61	6
2	XX.15 10 06	100	150	61	8
3	XX.20 10 06	100	200	61	10
4	XX.15 15 08	150	150	81	12
5	XX.16 50 15	500	162	151	51
6	XX.30 15 08	150	300	78	22
7	XX.30 15 13	150	230	131	22
8	XX.40 15 08	150	400	81	28
9	XX.20 20 08	200	200	81	19
10	XX.20 20 12	200	200	121	24
11	XX.30 20 08	200	300	81	27
12	XX.30 20 12	200	300	121	33
13	XX.30 30 19	300	300	195	56
14	XX.30 38 19	380	300	195	67
15	XX.30 38 21	380	300	211	70
16	XX.38 38 19	380	380	195	79
17	XX.40 20 12	200	400	121	42
18	XX.40 20 16	200	400	161	46
19	XX.60 20 12	200	600	121	59
20	XX.30 30 12	300	300	121	43
21	XX.30 30 15	306	306	151	50
22	XX.30 30 16	300	300	161	50
23	XX.40 30 16	300	400	161	63
24	XX.45 38 15	458	382	151	81
25	XX.50 30 16	300	500	161	76
26	XX.38 30 21	300	380	211	69
27	XX.38 38 16	380	380	161	71



Attachment to Certificate
IECEx PTB 07.0060 Issue 4



No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
28	XX.38 38 21	380	380	211	82
29	XX.40 40 16	400	400	161	77
30	XX.40 65 19	650	400	195	126
31	XX.50 40 16	400	500	161	92
32	XX.60 30 16	300	600	161	85
33	XX.60 38 21	380	600	211	115
34	XX.60 60 21	600	600	211	163
35	XX.60 70 19	700	600	195	179
36	XX.60 90 19	900	600	195	222
37	XX.76 76 21	760	760	238	250
38	XX.XX XX XX	max. 1200	max. 2000	max. 500	

Enclosure standard and max. Power Dissipation of Ex Stainless Steel Cabinets:

Type reference: Empty enclosure
34.00 XX XX Ex Stainless Steel Cabinets

Increased Safety
35.00 XX XX Ex Stainless Steel Cabinets

Intrinsic Safety / mixed assembled
36.00 XX XX Ex Stainless Steel Cabinets

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	34.XX 22 09	250	200	90	24
2	34.XX 22 15	250	200	150	32
3	34.XX 32 09	250	300	90	33
4	34.XX 32 15	250	300	150	42
5	34.XX 33 16	300	300	165	51
6	34.XX 34 21	300	380	215	70
7	34.XX 43 16	300	400	165	62
8	34.XX 52 09	250	500	90	50
9	34.XX 52 15	250	500	150	62
10	34.XX 53 16	300	500	165	74
11	34.XX 63 16	300	600	165	86
12	34.XX 44 16	380	380	165	72



Attachment to Certificate
IECEx PTB 07.0060 Issue 4



No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
13	34.XX 44 21	380	380	215	83
14	34.XX 64 21	380	600	215	116
15	34.XX 99 99	max. 1200	max. 2000	max. 500	

Enclosure standard and max. Power Dissipation of **Enclosure Flange 1. and 2. Generation:**

Type reference:

Empty enclosure

34.XX XX XX Ex Stainless Steel Flange 1. Generation

34.03 XX XX Ex Stainless Steel Flange 2. Generation

Increased Safety

35.00 XX XX Ex Stainless Steel Flange 1. Generation

35.03 XX XX Ex Stainless Steel Flange 2. Generation


Intrinsic Safety / mixed assembled

36.00 XX XX Ex Stainless Steel Flange 1. Generation

36.03 XX XX Ex Stainless Steel Flange 2. Generation

Stainless Steel Flange 1. Generation

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.12 12 09	120	120	90	9
2	XX.16 16 09	160	160	90	14
3	XX.13 18 13	180	130	130	17
4	XX.31 31 15	306	306	150	50
5	XX.46 38 15	460	380	150	80
6	XX.76 50 15	760	500	150	151
7	XX.92 61 20	920	610	200	232
8	XX.76 50 21	760	500	210	174
9	XX.76 50 25	760	500	250	189
10	XX.92 61 25	920	610	250	254
11	XX.92 61 30	920	610	300	277
12	XX.92 61 35	920	610	350	300
13	XX.XX XX XX	max. 1200	max. 2000	max. 500	



Ex Stainless Steel Flange 2. Generation

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.XX 33 01	306	306	217	61
2	XX.XX 43 01	382	458	217	96
3	XX.XX 75 04	508	762	217	175
4	XX.XX 86 04	640	860	217	230
5	XX.XX 97 04	740	980	217	288
6	XX.XX 99 99	max. 1200	max. 2000	max. 500	

Enclosure standard and max. Power Dissipation of **ProtEx Stainless Steel Flange**:

Type reference:

- Empty enclosure
 - 34.04 XX XX ProtEx electropolished
 - 34.05 XX XX ProtEx electropolished / Return Flange
 - 34.06 XX XX ProtEx polished
 - 34.07 XX XX ProtEx polished / Return Flange
- Increased Safety
 - 35.04 XX XX ProtEx electropolished
 - 35.05 XX XX ProtEx electropolished / Return Flange
 - 34.06 XX XX ProtEx polished
 - 34.07 XX XX ProtEx polished / Return Flange
- Intrinsic Safety / mixed assembled
 - 36.04 XX XX ProtEx electropolished
 - 36.05 XX XX ProtEx electropolished / Return Flange
 - 36.06 XX XX ProtEx polished
 - 36.07 XX XX ProtEx polished / Return Flange

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.XX 02 00	260	260	205	47
2	XX.XX 03 00	306	306	205	59
3	XXXX 04 00	380	260	205	63
4	XX.XX 05 00	458	382	205	94
5	XX.XX 06 00	480	480	205	114
6	XX.XX 07 00	500	350	205	95
7	XX.XX 08 00	620	450	205	134
8	XX.XX 09 00	740	550	205	180
9	XX.XX 10 00	762	508	205	174
10	XX.XX 11 00	860	640	205	229
11	XX.XX 12 00	914	610	205	233
12	XX.XX 13 00	980	740	205	286



Enclosure standard and max. Power Dissipation of **Enclosure Captive Clamp Ex flange:**

Type reference: Empty enclosure
 34.08 XX XX Captive Clamp

 Increased Safety
 35.08 XX XX Captive Clamp

 Intrinsic Safety / mixed assembled
 36.08 XX XX Captive Clamp

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.08 06 01	306	306	205	59
2	XX.08 06 02	350	480	205	90
3	XX.08 06 03	400	600	205	118
4	XX.08 06 04	450	382	205	93
5	XX.08 06 05	458	382	205	94
6	XX.08 06 06	508	762	205	170
7	XX.08 06 07	620	450	205	134
8	XX.08 06 08	620	450	230	142
9	XX.08 06 09	640	860	205	225
10	XX.08 06 10	640	860	230	236
11	XX.08 06 12	400	382	205	84
12	XX.08 06 13	450	620	230	139


Enclosure standard and max. Power Dissipation of **Enclosure Stainless Steel Special Size:**

Type reference: Empty enclosure
 34.XX XX XX Ex Stainless Steel Special Size

 Increased Safety
 35.XX XX XX Ex Stainless Steel Special Size

 Intrinsic Safety / mixed assembled
 36.XX XX XX Ex Stainless Steel Special Size


No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.00 90 51	380	600	217	117
2	XX.00 90 52	860	640	217	234
3	XX.00 90 53	400	450	217	98
4	XX.05 10 01	762	508	217	179
5	XX.20 20 12	200	200	121	24



Attachment to Certificate
IECEX PTB 07.0060 Issue 4




No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
6	XX.03 90 29	560	400	227	120
7	XX.03 90 30	306	250	205	52
8	XX.00 90 29	300	380	217	70
9	XX.00 90 30	306	306	217	61
10	XX.00 90 31	485	382	217	101
11	XX.03 90 31	340	306	200	63
12	XX.03 90 32	458	382	200	93
13	XX.03 90 33	480	480	200	113
14	XX.03 90 38	360	380	210	79
15	XX.03 90 43	425	380	210	89
16	XX.03 90 44	354	262	227	64
17	XX.03 90 45	454	502	227	119
18	XX.03 90 49	442	458	217	107
19	XX.03 90 50	90	51	185	226
20	XX.03 90 51	386	314	227	77
21	XX.03 90 52	300	380	217	70
22	XX.03 90 53	400	200	121	42
23	XX.90 90 29	236	176	150	28
24	XX.00 90 35	400	400	200	86
25	XX.03 90 54	980	740	400	385
26	XX.03 90 55	740	553	300	217
27	XX.03 90 56	500	350	300	119
28	XX.03 90 57	325	325	230	69
29	XX.03 90 58	325	325	200	64
30	XX.03 90 59	200	200	125	24
31	XX.03 90 60	500	500	200	120
32	XX.03 90 61	730	730	240	235
33	XX.03 90 67	306	306	200	58
34	XX.03 90 68	480	480	200	113
35	XX.03 90 69	300	400	200	69
36	XX.03 90 70	530	480	210	125
37	XX.90 90 32	600	300	161	89
38	XX.00 90 38	300	380	210	69
39	XX.03 90 71	470	420	227	108
40	XX.00 90 98	1400	800	400	545



Attachment to Certificate
IECEX PTB 07.0060 Issue 4




No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
41	XX.03 91 00	300	300	167	51
42	XX.03 91 01	600	600	217	165
43	XX.90 90 51	500	1000	400	291
44	XX.00 90 48	380	380	217	84
45	XX.03 91 03	500	300	160	75
46	XX.03 91 04	306	306	210	60
47	XX.03 91 05	350	350	180	67
48	XX.03 91 06	200	200	180	30
49	XX.03 91 07	500	450	200	111
50	XX.03 90 99	380	380	217	84
51	XX.03 91 02	250	200	157	33
52	XX.00 90 46	600	600	300	194
53	XX.00 90 49	500	300	160	75
54	XX.00 90 50	300	300	160	50
55	XX.90 90 57	800	600	280	236
56	XX.00 90 61	1200	1000	300	495
57	XX.00 90 62	380	380	161	71
58	XX.00 90 63	500	400	161	92
59	XX.03 91 08	300	350	160	56
60	XX.03 91 09	300	400	160	62
61	XX.03 91 10	200	200	160	28
62	XX.03 91 11	360	360	150	63
63	XX.00 90 54	525	375	210	105
64	XX.00 90 55	415	265	210	70
65	XX.00 90 56	500	350	200	94
66	XX.00 90 57	300	265	160	46
67	XX.00 90 58	200	200	120	23
68	XX.03 91 12	237	117	91	16
69	XX.90 90 53	727	360	190	128
70	XX.00 90 59	300	450	217	79
71	XX.00 90 60	300	380	217	70
72	XX.03 91 13	306	245	217	53
73	XX.03 91 14	382	458	217	96
74	XX.90 90 54	360	360	150	63
75	XX.90 90 55	237	177	91	21



Attachment to Certificate
IECEX PTB 07.0060 Issue 4



No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
76	XX.90 90 56	727	400	190	137
77	XX.03 90 75	600	380	217	120
78	XX.03 91 15	500	400	320	134
79	XX.00 90 65	400	400	300	109
80	XX.90 90 33	250	250	120	33
81	XX.90 90 42	120	120	80	9
82	XX.03 90 36	260	260	200	47
83	XX.03 90 66	260	260	150	39
84	XX.00 90 40	500	380	210	102
85	XX.03 90 72	380	380	210	82
86	XX.03 90 73	306	306	210	60
87	XX.03 90 74	1200	600	300	344
88	XX.03 90 76	1200	840	300	434
89	XX.03 90 77	1200	640	300	359
90	XX.90 90 39	600	400	210	122
91	XX.90 90 40	600	600	210	163
92	XX.90 90 41	1000	800	300	359
93	XX.90 90 38	400	400	210	88
94	XX.03 90 78	800	800	300	299
95	XX.03 90 79	1100	1100	300	495
96	XX.00 90 42	800	600	300	244
97	XX.03 90 83	150	150	130	16
98	XX.03 36 01	380	260	205	63
99	XX.03 90 84	600	400	200	119
100	XX.05 10 00	762	508	205	174
101	XX.90 90 44	500	400	217	107
102	XX.03 90 86	1130	750	300	380
103	XX.90 90 43	100	180	81	10
104	XX.90 90 48	100	100	81	7
105	XX.03 90 87	500	380	217	104
106	XX.03 90 88	300	300	160	50
107	XX.03 90 89	380	380	160	71
108	XX.03 90 91	500	400	161	92
109	XX.03 90 92	1000	1000	300	425
110	XX.03 90 94	760	560	280	216



Attachment to Certificate
IECEX PTB 07.0060 Issue 4



No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
111	XX.03 90 80	306	306	217	61
112	XX.03 90 81	150	150	130	16
113	XX.03 90 95	760	600	300	234
114	XX.03 90 96	360	360	150	63
115	XX.03 90 97	360	360	190	72
116	XX.00 90 45	670	470	360	200

The rated values are maximum values, the actual electrical values depend on the electrical equipment incorporated. Within the scope of these maximum permissible values and with due regard to the standards, the manufacturer specifies the final rated values dependent on the system conditions, mode of operation, utilization category, etc. The characteristic values of the intrinsically safe circuits are to be given by the manufacturer on his own responsibility. Further technical details have been specified in the test documents.

The composition of the symbol specifying the type of protection depends on the types of protection of the components used.

The maximum permissible ambient temperature range of the terminal housing can be limited by the maximum permissible ambient temperature ranges of the separately certified equipment.

Additional Advices

Components attached or installed (terminal compartments, bushings, Ex-type cable glands, connectors) shall be of a technical standard that at least complies with the specifications on the cover sheet, and they shall have a separate examination certificate. The operating conditions specified in the component certificates must definitely be complied with, and the operating instructions must include a note to inform the operating company of this equipment. The method used for assessing the suitability of the used component must be documented in a verifiable manner in compliance with the QM system.

For repair of separately certified components, the IECEx Examination for these components must be observed.

Equipment of the type of protection intrinsic safety "i" according to IEC 60079-11 is to be installed in such a way that the distances, creepage distances and clearances between intrinsically safe circuits and non-intrinsically safe circuits required according to EN 60079-14 are complied with.

When more than one intrinsically safe circuit is used, the rules for interconnection are to be observed.

Degree of protection IP66 will be safeguarded only when sealing and cable entry fittings are properly fitted. The manufacturer's instructions must be followed.

Installation of the components in the electrical apparatus shall be made such that the local temperatures will be within the operating temperature range.

Notes for manufacturing and operation

Each device needs to be evaluated concerning the max. allowed temperature limit according to the relevant temperature class and concerning the limiting temperature of the materials. This evaluation needs to be done within the engineering process and must be complemented by an additional temperature measurement in any case doubt. The admissible ambient temperature ranges of the build-in components may not be exceeded at the place of installation.

Physikalisch-Technische Bundesanstalt (PTB)

Bundesallee 100, 38116 Braunschweig, Germany
Postfach 33 45, 38023 Braunschweig, Germany
Telephone +49 531 592-0, Telefax +49 531 592-3605